

Maritime Office Building Chiller Replacement Project
Port of Palm Beach District
Riviera Beach, Florida

ADDENDUM No. 1
DATE 12/13/2010

ADDENDUM No. 1

Maritime Office Building (MOB) Chiller Replacement Project

DATE: December 14, 2010

PROJECT NO. RFP #2011-01

GENERAL:

- A. This Addendum modifies, changes from or adds to the Request for Proposal (RFP) Manual dated December 5, 2010 and all associated Addenda, and shall become a part of the RFP Documents.
- B. It is requested that the Proposers acknowledge receipt of this Addendum with their submittal.

Bid Form – Lump Sum

Please replace and complete the attached bid form and submit at the scheduled time and place for Bids. Add or deductive alternates will be used to increase or decrease the contract amount through a Port of Palm Beach approved change order.

Add or deductive alternates were established for the following items:

- Isolation Valves – cost per isolation valve
- Standby Chiller – cost per week, including hookup, mobilization and demobilization

Contract, Section 13.4

Section 13.4 has been deleted from this contract.

Exhibit A, Scope of Work - Clarifications

- The Contractor shall include in the base bid price, the replacement of up to four (4) isolation valves for the chiller replacement project.
- The condenser coating (Energy Guard or Blygold) process shall be completed in the factory. The coating shall be applied by dipping the condenser in the coating material or as specified by the manufacturer.
- If required, the contractor shall be responsible for the protection and/or repair of the existing elevators in the Maritime Office Building.

General

One of your fellow contractors was kind enough to supply me with the attached cut sheets for your use and information. The Port of Palm Beach District is passing this information on to you for your use and assumes no responsibility for the data included in these documents. The attached information does not relieve you of any responsibility for completing your own calculations or research.

ACKNOWLEDGE RECEIPT.

ADDENDUM No. 1

Maritime Office Building Chiller Replacement Project
Port of Palm Beach District
Riviera Beach, Florida

ADDENDUM No. 1
DATE 12/13/2010

Bidder acknowledges the receipt of Addendum numbers:

1. _____ 2. _____ 3. _____ 4. _____

Dated this _____ day of _____, 2010.

NAME OF THE PROPOSER: _____

ADDRESS OF THE PROPOSER: _____

BY: _____

TITLE: _____

END OF ADDENDUM NO. 1